



217/782-2113

JOINT CONSTRUCTION AND OPERATING PERMIT

PERMITTEE

The Sherwin-Williams Company
Attn: Robert C. Martin
11541 S. Champlain Avenue
Chicago, IL 60628

EPA Region 5 Records Ctr.



355927

Application No.: 87040037

I.D. No.: 031600AHO

Applicant's Designation: RB-OF1

Date Received: April 16, 1987

Subject: Natural Gas Boilers (1-400, 2-800 BHP)

Date Issued: May 18, 1987

Operating Permit Expiration

Date: April 16, 1992

Location: 11541 S. Champlain Avenue, Chicago

Permit is hereby granted to the above-designated Permittee to CONSTRUCT and OPERATE emission source(s) and/or air pollution control equipment consisting of one 400 BHP boiler and two 800 BHP boilers as described in the above-referenced application. This Permit is subject to standard conditions attached hereto and the following special condition(s):

1. Operation of the emission source(s) included in this permit shall not begin until all associated air pollution control equipment has been constructed and is operational.
2. Emissions of particulate matter and nitrogen oxides shall not exceed 0.22 tons/year and 4.43 tons/year, respectively. These limits are based on the maximum hours of operation and the maximum firing rate, indicated in the permit application.

Terry A. Sweitzer

Terry A. Sweitzer, P.E.
Manager, Permit Section
Division of Air Pollution Control

TAS:DAA:jmm/4238H/3

DAA
cc: Region 1
HCC